

Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504 (360) 407-9280 • fax (360) 586-5366 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc

STATE BUILDING CODE INTERPRETATION NO. 14-08

CODE: 2012 Washington State Energy Code, Commercial

SECTION: Appendix A

Table A105.1(1) - Default U-Factors Over Vented Crawlspace or

Unheated Basement

Table A105.1(2) - Default U-Factors For Floors Over Heated Plenum

Crawlspaces

QUESTION: Are the U-factors provided in Tables A105.1(1) and A105.1(2) only

for wood-framed floor assemblies?

ANSWER: Yes. See footnote "e" in Table C402.2

SUPERSEDES: None

REQUESTED BY: Pierce County